PBAT GATE Firmware Upgrade manual-V3.3



PILOT (HENGQIN) CO., LTD

Step1: Login the system

Use the "Chrome or "browser. Login to the gateway's

web page. The default account is as follows:

Username: admin

Password: admin



Step2: Gateway Firmware Upgrade

Click the left menu bar "Setting" -> "General Setting" -> "Gateway firmware upgrade" to display the gateway

firmware upgrade page.



And then click "Add File"

Diat	BMS	English 中文	Version: V3.3-20180423 🕑 Log out
admin(Administrator	Firmware Upgrade		
📰 Real-Time Data	+ Add File		
네 Historical Data			6
🛃 Discharge Data			
😐 Reports			
Fault Statistics			
▲ Real-Time Alarm			
Historical Alarm			
¢\$ Setting ∽			
Parameter Setting			
Network Setting			
Serial Port Setting			
Input Setting			
Alarm Setting			
CommDebug	派诺科技蕾电池测试房1#电池组		珠海横琴派诺技术有限公司 © 2017

Then select the new version of the upgrade package, and click "**Open**" in the lower right corner.





Firmware Upgrade		
+Add File		
20180423-PGATE-Online- 16.31 MB V3.3.zip	1	0

Waiting for upgrade.

Firmware Upgrade	
+ Add File	
	7.59 Mbit/s 00:00:00 100.00 % 16.31 MB / 16.31 MB
20180423-PGATE-Online- 16.31 MB V3.3.zip	±

After the progress bar disappears, the upgrade is complete.

Step3: Clear browser cache

Use the "Chrome" browser,

then use shortcut keys: "Ctrl+H",

Select the "Clear browsing data"



1.Select "Advanced"

2.Time range: All time

3. Select all items





The upgrade is complete, log in to see the effect.

Thanks for watching!

Notice:

- PILOT reserves the right to modify this manual without prior notice in view of continued improvement
- Please use the "Chrome on "browser, system is not compatible with IE browser.
- Email: marketing@pmac.com.cn systemtech@pmac.com.cn

PILOT (HENGQIN) CO., LTD

Add:No.15,keji6Road,Chuangxin Haian, Tangjia High-tech

Zone, Zhuhai, Guangdong, 519085 China

Tel: +86-756-3639029

Fax: +86-756-3631718

http://en.pmac.com.cn



Wechat Official Accounts